

熱灼減量測定結果

採取場所：灰押し装置

採取日	号炉	測定結果 (%)	備考
R06. 04. 17	1	2. 8	湿灰
	2	4. 6	湿灰
R06. 05. 13	1	3. 1	湿灰
	2	5. 4	湿灰
R06. 06. 11	1	3. 9	湿灰
	2	4. 8	湿灰
R06. 07. 11	1	3. 5	湿灰
	2	4. 4	湿灰
R06. 08. 06	2	3. 4	湿灰
	3	3. 9	湿灰
R06. 09. 03	2	3. 1	湿灰
	3	3. 6	湿灰
R06. 10. 29	2	3. 9	湿灰
	3	5. 2	湿灰
R06. 11. 13	2	3. 4	湿灰
	3	3. 0	湿灰
R06. 12. 11	1	3. 7	湿灰
	3	5. 1	湿灰
R07. 01. 08	1	2. 3	湿灰
	3	4. 1	湿灰
R07. 02. 10	1	3. 4	湿灰
	3	3. 1	湿灰
R07. 03. 04	1	4. 0	湿灰
	3	3. 0	湿灰